

REPORT
for IP – 65 TEST

Report No. : E 9793001

Applicant : **ILINOX S.r.l.**
Via Anna Magnani, 11/A
I – 43056 San Polo (PR)

Test Object : Empty Computer Cabinet
(*Contenitori per Computer*)

Type Designation : APC608TR, APC616TR
APC608C, APC616C

Test Specification : EN 60529 :1991

Representativ Sample : APC608C and APC616TR

Test Result : in compliance with the a.m. test specification


1. Protection against water : IPX5 (Model APC608C)
No water ingressed (*non si è verificato ingresso d'acqua*)

2. Protection against ingress of dust : IP6X , Categorie 2 (Model APC616TR)
No dust ingressed (*non si è verificato ingresso di polvere*)

This report is the result of a singular test performance on the presented product. It does not authorized to use a GS mark or another mark on the product.

Mazzo di Rho, 20.10.1997

The expert



Ing. D. Behrendt