

## ATTESTATION OF CONFORMITY

No. 03I1272.01

Issued to: Ilinox S.r.l.  
Via A. Magnani, 11A I-43056 San Paolo (PR) Italy

For the product: Enclosure

Trademark: Ilinox

Model: KR/45

Manufactured by: Ilinox S.r.l.  
Via A. Magnani, 11A – 43056 San Paolo (PR) Italy


Tested according: EN 60529:91 + A1:00


Results: Sample were tested and found to be in conformity with the requirements for Protection Degree IP 45.

This Attestation refers to the tests made at KEMA Quality Italia S.r.l. The detailed results of the tests are laid down in our report: No. 03I1272.50

The tests have been carried out on a representative sample submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of the production with the specimen tested by KEMA is not the responsibility of KEMA.

KEMA Quality Italia S.r.l.  
Osnago (LC), July 11, 2003

  
De Simone Alfredo  
Test Engineer

  
Luca Porcu  
Project Leader

Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

**KEMA Quality Italia S.r.l.**

Via Martiri della Liberazione, 12 23875 Osnago (LC), Italy.  
Telephone +39 039 9280177, Telefax +39 039 9280294.