

# CERTIFICATE of Conformity



Registration No.: AK 60124713 0001

Report No.: 28110928 001

Holder: Ilinox S.r.l.  
Strada Provinciale Asolana 4/6  
43056 S. Polo di Torrile PR  
Italia

Product: Control Cabinet  
(empty enclosure for low-voltage switchgear)

Identification:	Designation	Dimension	Weight
	QLP816	805 x 1600 x 400 mm	94 kg
	PS064/304	600 x 400 x 150 mm	18 kg
	BK65	600 x 500 x 150 mm	13 kg

IP Degree : IK 10 ; IP 66 or IP69K

Tested acc. to: IEC 62262:2002  
IEC 60529:1989+A1+A2

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date 09.11.2017

Certification Body  
A handwritten signature in blue ink over the circular stamp.  
F. Ceriani  
A circular blue stamp with the TÜVRheinland logo in the center. The text around the logo reads 'TÜV Rheinland LGA Products GmbH' at the top and 'Zertifizierungsstelle' at the bottom.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg