

## ATTESTATION OF CONFORMITY

No. 02I1367.01

Issued to: ILINOX S.r.l.  
Via A. Magnani, 11 - 43056, San Polo (Parma), Italy

For the product: Industrial Panels series ML, MV, QL, QV, QLP (without fairlead plate) and series MC (with glazed doors or blind doors).  
The industrial panels are all single door.

Trademark ILINOX

Manufactured by: ILINOX S.r.l.  
Via A. Magnani, 11 - 43056, San Polo (Parma), Italy

Tested according: EN60529/A1:2000

Results: Samples of the series were tested and found to be in conformity with the requirements for Protection Degree IP 66.

This Attestation refers to the tests made at KEMA Quality Italia S.r.l. The detailed results of the tests are laid down in our report: No. 02I1367.50

The tests have been carried out on four representative samples of the Model: ML056, MV068, QL36, QL66, QL812, QLP68, QV34, QV710 and MC0606, MC1008 submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of the production with the specimen tested by KEMA is not the responsibility of KEMA.

KEMA Quality Italia S.r.l.  
Carnate (MI), November 04, 2002

Biagio Di Sanzo  
Testing Engineer



Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

**KEMA Quality Italia S.r.l.**  
Via I Maggio 13, 20040 Carnate (MI), Italy.  
Telephone +39 039 674314, Telefax +39 039 6753431.