

ATTESTATION OF CONFORMITY

No. 0311425.01

Issued to:	Ilinox S.r.l. Via A. Magnani, 11A I-43056 San Paolo (PR) Italy
For the product:	Enclosure
Trademark	Ilinox
Model	KR/55
Manufactured by:	Ilinox S.r.l. Via A. Magnani, 11A – 43056 San Paolo (PR) Italy
Tested according:	EN 60529:91 + A1:00
Results:	Sample were tested and found to be in conformity with the requirements for Protection Degree IP 55.

This Attestation refers to the tests made at KEMA Quality Italia S.r.l. The detailed results of the tests are laid down in our report: No. 0311425.50

The tests have been carried out on a representative sample submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of the production with the specimen tested by KEMA is not the responsibility of KEMA.


KEMA Quality Italia S.r.l.
Osnago (LC), October 03, 2003

De Simone Alfredo
Test Engineer



Luca Porcu

Project Leader



Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality Italia S.r.l.

Via Martiri della Liberazione, 12 23875 Osnago (LC), Italy.
Telephone +39 039 9280177, Telefax +39 039 9280294.